


# PRODUCT CERTIFICATE OF REGISTRATION



## Global Certification Pty Ltd Number 476

Product Performance Testing

### AS 1546.3:2017

## Advanced Secondary 1200 Litres per day (8EP) Level

Issued to

### FujiClean Australia Pty Ltd

PO Box 1230 Oxenford Qld 4210

Certification Date:- 16<sup>th</sup> March 2019 Expiry Date:- 15<sup>th</sup> March 2024

#### Product Certified:

Model	Disinfection	Average Results over the test period	Servicing Frequency	Discharge	Manufactured and Assembled	
FujiClean ACE 1200 8EP Advanced Secondary System AWTS	Yes	TSS 2.9mg/l BOD <sub>5</sub> <2mg/l Total Nitrogen 14.79mg/l Phosphorus 10.33mg/l Turbidity 3.63NTU E coli <1 CFU/100ml	3 monthly Sedimentation pump out 5 yearly or when required	Pumped via disinfection/pump chamber with chlorine dispenser	59 Computer Road Yatala Qld 4207	
Description	Total size	Sedimentation Chamber	Anaerobic Filtration Chamber	Aerobic Contact Filtration Chamber	Clarification Chamber	Disinfection/Pump Chamber
Working capacity	3,265 L	1,114 L	982L	580L	281L	308L
Total capacity				4,369 L		
Emergency storage capacity				1,104 L		

**NACE CODES:** 2221, 2829, 3700

This Certificate of Conformance to the Product Certificate Scheme for "Domestic Wastewater Treatment Units (Septic Tanks) and Rainwater Tanks" remains the property of Global Certification Pty. Ltd. and is granted subject to the terms and conditions of the Contract Application, in respect of the Product certified on this page and the attached schedule to the Certification of Conformance, bearing the same number as this certificate.

Date of Issue: 2<sup>nd</sup> April 2021

**Bruce Smith Director**



[www.jas-anz.com.au/register](http://www.jas-anz.com.au/register)

Signed for and on behalf of Global Certification Pty Ltd  
PO Box 953 Belconnen ACT 2616

© Global Certification Pty Ltd GC0050B R5 January 2021